

Optimized Maximum Loadability of Power Systems using an Enhanced Dynamic JAYA Algorithm

Ibrahim A. Farhat^{1*}, Abdullah O. Hawal²

¹ ibrahimfarhat@yahoo.com, ² aohawal@elmergib.edu.ly

¹ Electrical and Computer Engineering Department, Faculty of Engineering, Al-Asmarya University, Libya

² Electrical and Computer Engineering Department, Faculty of Engineering, Elmergib University, Libya

*Corresponding author email:

ABSTRACT

The problem of Maximum Loadability of power systems is addressed in this paper using a proposed dynamic JAYA algorithm. The maximum loadability problem is a typical optimization problem in which the maximum loadability point is to be determined optimally. Voltage stability of power systems is maintained by determining the estimated margin between the system operating point and the maximum loadability limit. The basic JAYA algorithm has been introduced to solve foremost optimization problems with small-scaled nature. However, when applied to large-scale, nonlinear and non-convex constrained problems, it showed a poor convergence characteristics. In order to deal with these weaknesses, the original algorithm has been improved by adding some dynamic features to its convergence behavior. The modified algorithm has been presented and validated when applied to well-known typical power systems. The obtained results were compared to the results achieved by other equivalent optimization techniques.

Keywords: JAYA algorithm, maximum loadability limit, power system optimization, voltage stability.

1 Introduction

Voltage instability is one of the common operation problems accompanying power system networks as a result of various operating conditions. To deal with this issue and maintain voltage stability after the occurrence of disturbances in the system, the state of equilibrium has to be restored successively. One of the most effective reasons behind the voltage instability is the extensively stressed and heavily loaded systems. Shortage of reactive power supply that does not satisfy the demand is another possible reason. Switching problems, unscheduled outages in addition to poor system voltage profiles can also cause voltage instability and lead the system to loose equilibrium. Obviously, voltage collapse can be experienced in different

parts of the network [1]. Although they are linked to each other, maximum loadability and voltage stability concepts should not be mixed up. One should think of maximum loadability problem considering the system static characteristics and not limited by the voltage stability aspects. Nevertheless, the closer the system operating point to the maximum loadability limit, the more likely the voltage instability to occur [2]. Figure 1 shows the P-V curve demonstrating the nose point of the maximum loading point.




Figure 1: P-V curve and maximum loadability limit

As shown in the figure, the system operates in the upper part of the curve with static and dynamic stability characteristics are feasible. In this region, the curve has a high voltage-low current profile. The maximum loadability limit point defines the voltage collapse point behind which the system loses equilibrium [1]. Optimization methods in general can be classified as classic deterministic and heuristic non-deterministic techniques. Many of these have been applied to solve the maximum loadability optimization problem. Among the deterministic calculus-based approaches are the Interior Point method and the Sequential Quadratic Programming algorithms [3, 4]. More recent heuristic methods have also been utilized successfully to solve this problem. These include Particle Swarm Optimization (PSO) [5], Ant Colony Optimization (ACO) [6] and Genetic Algorithm (GA) [7]. The JAYA algorithm is one of the heuristic non-calculus-based approaches that have been applied for optimization problems. This algorithm has recently introduced as a simple and non-deterministic optimization technique [8]. In spite of its popularity and simplicity due to the limited number of parameters it requires, the basic JAYA algorithm suffers from significant convergence issues. This poor convergence behavior can be observed when applying the basic algorithm to nonlinear, nonsmooth high-scaled optimization problems with nonlinear constraints. The major weakness is the divergence to local minima instead of converging to the global. It was observed through the experience and trials that some population diversity preservation issues were the reason behind this deficiency. In this paper, a modified adaptive JAYA algorithm, MAJAYA, is presented and applied to determine the maximum loadability limit of power systems. The reminder of the paper is organized as follows: Section 2 provides the formulation

of the problem. In Section 3, the MAJAYA is described. Simulation results are demonstrated in Section 4. The conclusion is drawn in Section 5.

2 Maximum Loadability

The optimization problem of the Maximum Loadability is formulated as a nonlinear constrained optimization problem [3].

2.1 Objective Function

The objective of the problem is to find the maximum loading of a power system taking into consideration the operational constraints of the system [3]. The maximum loadability problem is formulated as follows:

$$\text{Max } f = \lambda \quad (1)$$

where λ is the load incremental parameter with reference to the current operating point of the system. This parameter is bounded by its *initial* value which is 0 and its upper limit $\lambda_{collapse}$ at the voltage collapse point. Accordingly, the power demand of the buses increases instantaneously as follows:

$$P_{di} = P_{d_{i0}} + \lambda P_d \quad (2)$$

$$Q_{di} = Q_{d_{i0}} + \lambda Q_d \quad (3)$$

P_{di} and Q_{di} are the active and reactive power at the i^{th} load bus, while $P_{d_{i0}}$ and $Q_{d_{i0}}$ are the *initial* active and reactive power at the i^{th} load bus.

2.2 Constraints

The system constraints include bus voltage magnitude limits, power generation upper and lower limits, switchable capacitor limits and transformer tap changer limits.

- Load balance

$$P_{gi} - P_{di} = |V_i| \sum_{j=1}^N |Y_{ij}| |V_j| \cos(\delta_i - \delta_j - \theta_{ij}) \quad (4)$$

$$Q_{gi} - Q_{di} = |V_i| \sum_{j=1}^N |Y_{ij}| |V_j| \sin(\delta_i - \delta_j - \theta_{ij}) \quad (5)$$

where the number of buses is N and the voltage profile of the i^{th} bus is $|V_i|$ and δ_i while the i^{th} element of the system's Y_{bus} matrix is $|Y_{ij}|$ and θ_{ij} .

- Power generation upper and lower limits

$$P_{gi,min} \leq P_{gi} \leq P_{gi,max} \quad (6)$$

$$Q_{gi,min} \leq Q_{gi} \leq Q_{gi,max} \quad (7)$$

- Bus voltage magnitude and angle limits

$$|V|_{min} \leq |V|_i \leq |V|_{max} \quad (8)$$

$$\delta_{i,min} \leq \delta_i \leq \delta_{i,max} \quad (9)$$

- Transformer tap changer limits

$$T_{k,min} \leq T_k \leq T_{k,max} \quad (10)$$

- Switchable capacitor limits

$$Q_{ci,min} \leq Q_{ci} \leq Q_{ci,max} \quad (11)$$

In the above equations; the number of generating units is N_g , the number N_b is the number of system buses, N_t is the number of tap changing transformers and N_s is the number of switchable shunt capacitors.

3 The JAYA Algorithm

This section is divided into two parts. In the first the basic JAYA is explained. The modified JAYA algorithm is demonstrated in the second part.

3.1 The Basic JAYA Algorithm

The original JAYA algorithm is a deterministic heuristic optimization method that was introduced by R. Venkata [8] recently. JAYA is a Sanskrit word which means victory. This approach has been effectively applied to solve a number of constrained optimization problems. The very limited number of control parameters required for this algorithm is one of its good features. A short explanation on how the JAYA algorithm can be implemented is shown as follows:

- 1- The population size, number of variables for decision and stopping criteria are defined and the process is initialized.
- 2- Population of size P (candidate solution) \times q (decision variables) is generated.
- 3- An initial solution is determined.
- 4- Best and worst solutions ($X_{i,best}^k, X_{i,worst}^k$) are computed.
- 5- The solution vector is updated as follows:
$$X_{i,j}^{k+1} = X_{i,j}^k + r_1(X_{i,best}^k - |X_{i,j}^k|) - r_2(X_{i,worst}^k - |X_{i,j}^k|) \quad (12)$$
where, r_1 and r_2 are random numbers within the interval [0, 1].
- 6- Solution candidates are compared to check if the updated solution is better than the previous one or not. The update is accepted if the new candidate is better, otherwise it is rejected.
- 7- The stopping criterion is checked and applied so that the algorithm is terminated when satisfied or otherwise return to update step 2.

The JAYA algorithm requires identifying only the maximum iteration in addition to the size of population. It can also be seen from Equation (12) that the candidate moves closer to the best solution and pushes away from the worst one.

3.2 The Modified Adaptive JAYA Algorithm

In order to deal with the hitches linked to the basic algorithm, some changes are suggested in this section. These modifications are introduced to improve the algorithm's behaviour when applied for large nonlinear nonsmooth objective functions.

The proposed adjustment is to dynamically update the population size. Accordingly, once the initial population size is chosen, then the population size is updated adaptively according to the following mechanism [9]:

$$P_{new} = P_{old} \times \text{round}(1 + s) \tag{13}$$

In the above equation s is an arbitrary variable such that $-1 < s < 1$. Consequently, in the modified adaptive algorithm (MAJAYA), all the population elements will be updated to the next population vector if the new size is larger than the old one and the optimal solution will be assigned to the remaining candidates. On the other hand, only the best solution will be moved to the next population if the old size is larger than the new one. Logically, no action is needed if there is no change in the size.

4 Simulation Results

The proposed MAJAYA was employed to determine the maximum (optimal) loadability for two well-known IEEE 30 bus and IEEE 118 bus power systems. The algorithm was implemented and coded in MATLAB and executed on an Intel Core i7-8750H 2.20GHz personal computer with 8 GB RAM. In order to check for consistency, 50 independent runs were conducted with different random initial solution for each run. Results obtained were compared with those of some other methods. The various algorithm parameters were tuned independently since they were problem-dependent. A considerable number of preliminary runs were executed individually so that the optimal parameter combination was obtained.

The IEEE 30 bus system consists of six generating units, four transformers and 41 branches. The system configuration can be found in [10]. Results obtained for maximum bus voltage amplitude and angle at the maximum loading point are shown in Table 1.

Table 1: 30 bus system: Bus voltages at the maximum loading.

Bus No.	Bus Voltage		Bus No.	Bus Voltage	
	V pu	δ°		V pu	δ°
1	1.0000	0.0000	16	0.9888	-12.0034
2	0.9998	-3.4534	17	0.9829	-12.7768
3	0.9758	-4.5678	18	0.9890	-12.8876
4	0.9897	-4.7856	19	0.9756	-12.8899
5	0.9876	-5.8783	20	0.9987	-12.8987
6	0.9843	-5.9723	21	0.9991	-12.6589
7	0.9887	-7.7685	22	0.9978	-13.0000
8	0.9954	-8.3334	23	0.8936	-13.1432
9	0.9865	-9.7683	24	0.9778	-12.8798
10	1.0000	-10.8721	25	0.9878	-11.5678
11	0.9788	-10.9867	26	0.9788	-11.5453
12	0.9878	-10.9999	27	1.0000	-11.3485
13	0.9877	-11.4638	28	0.9789	-11.5456
14	0.9856	-11.4537	29	1.0000	-12.7776
15	0.9867	-11.6665	30	0.9819	-12.6799

The proposed algorithm was once again applied to the IEEE 118 bus test system to confirm its effectiveness. The diagram of the testing system can be found in [10]. This system is made up of 54 generation buses, 64 load buses, and 186 branches. It also has 9 transformers and 14

switchable capacitor bank.

The results were compared to those obtained by some other evolutionary techniques previously employed to solve the problem. These are Differential Evolution (DE) [11], Multi Agent-based Hybrid Particle Swarm Optimization (MAHPSO) [12], Cuckoo Search Algorithm (CSA) [13] and Dynamic Modified Bacterial Foraging Algorithm (DMBFA) [14]. The comparison is demonstrated in Table 2.

Table 2: Comparison of the results.

Method	Maximum power (pu)	
	30-bus system	118-bus system
MAHPSO	2.6081	56.45
DE	2.6709	56.543
CSA	2.8396	62.5671
DMBFA	2.9284	62.9865
MAJAYA	2.9307	62.9888

5 Conclusions

In this paper, a modified adaptive JAYA algorithm was applied to determine the maximum loadability of power systems. This problem was addressed as an optimization problem and formulated as so. The system's operation constraints were taken into account. These included voltage magnitude limits, power generation upper and lower limits, switchable capacitor limits and transformer tap changer limits. The adaptive algorithm was modified to update the solution vector and enhance the convergence properties of the algorithm. Simulation results demonstrated the robustness and effectiveness of the algorithm for the maximum loadability problem. The algorithm was tested and applied to two well-known IEEE power systems. Comparison with some selected heuristic optimization methods showed that the applied algorithm has accomplished good and satisfying results compared to those obtained by the other techniques.

References

- [1] P. Kundur, "Power System Stability and Control", McGraw –Hill, 1994.
- [2] K. R. Padiyar, "Power System Dynamics: Stability and Control", BSP, 2nd ed., 2008.
- [3] G. D. Irisarri, X. Wang, J. Tong, S. Muktari, "Maximum loadability of power systems using interior point non-linear optimization method," IEEE Trans. Power Systems, vol. 12, no. 1, Feb. 1997, pp. 162–172.
- [4] V. Ajjarapu and C. Christy, "The continuation power flow: A tool for steady state voltage stability analysis", IEEE Trans. Power Systems, vol. 7, no. 1, Feb. 1992, pp. 416-423.
- [5] L. D. Arya, S. C. Choube, M. Shrivastava, and D. P. Kothari, "Loadability margin enhancement using coordinated aggregation based particle swarm optimization (CAPSO)" Int. J Electr Power Energy Syst., vol. 32, no. 9, 2010, pp. 975-984.
- [6] M. R. Kalil, I. Musirin, and M. M. Othman, "Ant colony optimization for maximum loadability search in voltage control study," Conference 2006 IEEE International Power and Energy, Nov. 2006 , Putra Jaya , pp. 240 – 245.
- [7] P. Acharjee, "Identification of Maximum Loadability Limit and Weak Buses using Security Constraint Genetic Algorithm", International Journal of Electrical Power and Energy Systems, vol. 36, pp. 40-50, 2012.
- [8] R. Venkata Rao, "Jaya: A simple and new optimization algorithm for solving constrained and unconstrained optimization problems," International journal of industrial computations vol.7, pp. 19-34, 2016.

- [9] I. A. Farhat, "Optimal Economic Dispatch of Thermal-Wind Power Systems with Valve-Point Effects using a Modified JAYA Algorithm," *International Journal of Engineering and Information Technology*, Vol.1, No.1, pp.1-5, December 2019.
- [10] R. D. Zimmerman, C.E. Murillo-Sánchez and R.J. Thomas, "MATPOWER Steady-State Operations, Planning and Analysis Tools for Power Systems Research and Education," *Power Systems, IEEE Transactions on*, vol. 26, no. 1, pp. 12-19, Feb. 2011.
- [11] K. Gnanambal, C.K. Babulal "Maximum loadability limit of power system using hybrid differentialevolution with particle swarm optimization," *Int. J. Electrical Power and Energy Systems*, vol. 43, no. 1, Dec. 2012, pp. 150-155.
- [12] A. Shunmugalatha, S. Mary Raja Slochanal, "Maximum loadability of a power system using multi agent-based hybrid particle swarm optimization," *Electr Power Compon Syst* vol. 36, no. 6, May 2008, pp. 575-86.
- [13] D. N. Vo and K.T. Vo, "Cuckoo Search Algorithm for Maximum Loadability of Power Systems," *GMSARN International Journal*, vol. 10, no. 1, 2016, pp. 137 - 144.
- [14] I. A. Farhat, "A Dynamic Bacterial Foraging Search Algorithm for Maximum Loadability of Power Systems," accepted for publication at the 3rd International Conference on Technical Science, icts2020.